

## **Appendix II-A – Recommended Standard Notes for Construction Stormwater Pollution Prevention Plans**

---

The following standard notes are suggested for use in Construction Stormwater Pollution Prevention Plans (SWPPPs). The City may have other mandatory notes for construction plans that are applicable. Plans should also identify with phone numbers and email addresses the person or firm responsible for the preparation of and maintenance of the Construction SWPPP.

### ***Standard Notes***

Approval of this Construction SWPPP does not constitute an approval of permanent road or drainage design (e.g., size and location of roads, pipes, restrictors, channels, retention/detention/infiltration facilities, utilities, etc.).

The implementation of this Construction SWPPP and the construction, maintenance, replacement, and upgrading of these Construction SWPPP facilities is the responsibility of the applicant/contractor until all construction is completed and approved and vegetation/landscaping is established.

The boundaries of the clearing limits shown on this plan shall be clearly flagged in the field prior to construction. During the construction period, no disturbance beyond the flagged clearing limits shall be permitted. The flagging shall be maintained by the applicant/contractor for the duration of construction.

The Construction SWPPP facilities shown on this plan must be constructed in conjunction with all clearing and grading activities, and in such a manner as to ensure that sediment and sediment laden water do not enter the drainage system, roadways, or violate applicable water standards.

The Construction SWPPP facilities shown on this plan are the minimum requirements for anticipated site conditions. During the construction period, these Construction SWPPP facilities shall be upgraded as needed for unexpected storm events and to ensure that sediment and sediment-laden water do not leave the site.

The Construction SWPPP facilities shall be inspected daily by the applicant/contractor and maintained as necessary to ensure their continued functioning.

The Construction SWPPP facilities on inactive sites shall be inspected and maintained a minimum of once a month or within the 48 hours following a major storm event.

At no time shall more than 1-foot of sediment be allowed to accumulate within a trapped catch basin. All catch basins and conveyance lines shall be cleaned prior to paving. The cleaning operation shall not flush sediment laden water into the downstream system.

Stabilized construction entrances shall be installed at the beginning of construction and maintained for the duration of the project. Additional measures may be required to ensure that all paved areas are kept clean for the duration of the project.

